



Type 202530
µP transmitter / controller
for pH value

B 20.2530.0.1
Operating Instructions

11.02/00401712

1	General	4
1.1	Preface	4
2	Typographical conventions	5
2.1	Warning signs	5
2.2	Note signs	5
3	Application	6
3.1	Type 202530	6
3.2	Operating Instructions B 20.2530.0.1	7
4	Instrument identification	8
4.1	Type designation	9
5	Instrument description	10
5.1	Technical data	10
5.2	Dimensions	13
5.3	Optional accessories	13
6	Assembly	15
6.1	Location	15
6.2	Fitting	15
6.3	Removing the controller module	16
6.4	Cleaning the front panel	16
7	Installation	17
7.1	Electrical connection	17
7.2	Connection diagram	18
7.3	Assembling the BNC plug	21
8	Commissioning	22
8.1	Self-test	22

9	Operation	23
9.1	Basics	23
9.2	Principle of operation	24
9.3	Operation within levels	25
9.4	General	26
9.5	Programming	27
10	Controller	28
10.1	Configuration	28
10.2	Controller optimization	30
11	Calibration	31
11.1	Preparation	31
11.2	One-point calibration	33
11.3	Two-point calibration	34
12	Operating level	35
12.1	Settings	35
13	Parameter level	36
13.1	Settings	36
14	Configuration level	38
14.1	General	38
14.2	Analog inputs - C111	38
14.3	Logic inputs... - C112	39
14.4	Serial interface... - C113	40
14.5	Other settings - C114	41
14.6	Controller options - C211	42
14.7	Controller outputs - C212	43
14.8	Other outputs I - C213	44
14.9	Other outputs II - C214	45
14.10	Response for HOLD / Overrange - C215	47
14.2	SoL - SoH - SPL - SPH - OFFS - nuLL - SLoP	48
15	Manual operation	50
15.1	Manual operation for outputs K1, K2 or K3	50
15.2	Simulated process value output	51

16	Hold	52
16.1	Hold controller	52
17	Version	53
17.1	Display software version and temperature unit	53
18	Logic inputs	54
18.1	Functions	54
19	Interface	55
19.1	MODbus /Jbus	55
19.2	Profibus-DP	56
20	Glossary	57
21	Warnings – Errors	64
21.1	Messages	64
22	Appendix	67
22.1	Programming the controller	67

1 General

1.1 Preface

Please read these Operating Instructions before commissioning the instrument. Keep the manual in a place that is accessible to all users at all times.

Please assist us to improve these operating instructions, where necessary.

Your suggestions will be welcome.

Phone +49 661 6003-0

Fax +49 661 6003-607



All necessary settings are described in this manual. However, if any difficulties should still arise during start-up, please do not carry out any unauthorized manipulations on the instrument. You could endanger your rights under the instrument warranty!

Please contact the nearest subsidiary or the main factory in such a case.



When returning modules, assemblies or components, the rules of EN 100 015 "Protection of electrostatically sensitive components" must be observed. Use only the appropriate **ESD** packaging for transport.

Please note that we cannot accept any liability for damage caused by ESD (electrostatic discharge).

2 Typographical conventions

2.1 Warning signs



Danger

This symbol is used when there may be **danger to personnel** if the instructions are ignored or not followed correctly!



Caution

This symbol is used when there may be **damage to equipment or data** if the instructions are ignored or not followed correctly!

2.2 Note signs



Note

This symbol is used when your **special attention** is drawn to a remark.

see abcd

Reference

The cursive (italic) text refers to **further information** in other chapters or sections.

abc¹

Footnote

Footnotes are remarks that **refer to specific points** in the text. Footnotes consist of two parts:

A marker in the text, and the footnote text.

The markers in the text are arranged as continuous superscript numbers.

*

Action


This symbol indicates that an **action to be performed** is described.

The individual steps are marked by this asterisk.

Example:

* Remove crosspoint screws.

* Press the  key.



Key combinations

If key symbols are shown connected by a plus sign, this means: first press and hold down the  key, and then press the next key.

3 Application

3.1 Type 202530

Description The compact microprocessor transmitter/controller, with 96mm x 48mm bezel and plug-in controller module, measures and controls the pH value or the redox potential (depending on the configuration) of aqueous solutions.

Inputs The transmitter has two analog and two logic inputs. The first analog input is suitable for connecting a pH combination electrode, or a glass and reference electrode (also antimony), or a redox combination electrode, or a metal and reference electrode. The second analog input can be used to connect Pt100 or Pt1000 resistance thermometers.

Display The instrument features two 4-digit 7-segment displays for indicating the pH or redox voltage process values (red) and the temperature (green). During programming, the displays provide comments on the inputs.

Outputs The instrument has a maximum of 5 outputs

Out-put	Stand-ard	Description / configurable	Output
K1	yes	Controller / controller off, limit controller, pulse width controller, pulse frequency controller, modulating controller with P, PI, PD or PID action	relay, make
K2	yes	Controller / controller off, limit controller, pulse width controller, pulse frequency controller, modulating controller with P, PI, PD or PID action	relay, make
K3	Option	Analog output / proportional controller	-- / analog
K3	Option	Limit comparator	relay, changeover contact
K4	yes	Logic output	0/5 V 0/10V
K5	Option	Analog output / proportional controller	-- / analog
K5	Option	Limit comparator	relay, changeover contact
K5	Option	Serial interface / Profibus-DP or MODbus/Jbus	RS422 / RS485

3.2 Operating Instructions B 20.2530.0.1



The Operating Instructions **B 20.2530.0.1** (Part No. 00401712) **only** deal with **the functions of the instrument when configured as a pH transmitter/controller!**

If the instrument has been configured as a **redox transmitter/controller**, then the Operating Instructions **B20.2535.0.1** (Part No. 00401713) have to be used!

These operating instructions provide full instructions on the installation, electrical connection, commissioning, operation, parameter setting and configuration of the microprocessor transmitter/controller for pH value, Type 202530.

4 Instrument identification


Check for completeness

You should have received at least the following:

- Transmitter/controller for pH value or redox voltage, Type 202530
 - 2 mounting brackets
 - 1 BNC plug
 - Seal (housing/panel)
 - Operating Instructions B 20.2530.0.1 and B 20.2535.0.1
-

Nameplate

The nameplate is glued to the housing.



Explanation of the type designation (1)

⇒ Chapter 4.1 “Type designation”, page 9.

The type designation (1) contains all the factory settings, such as the controller function, the measurement inputs and extra codes. The extra codes are listed in sequence and separated by commas.



The supply voltage must correspond to the voltage given on the nameplate (2).

4.1 Type designation

(1) Basic type	
202530	Microprocessor transmitter/controller for pH value (can be changed over to redox voltage)
(2) Basic type extensions	
00	controller off ¹
10	limit controller ¹
21	pulse width controller ¹
31	pulse frequency controller ¹
(3) Output I	
000	no output
310	relay, changeover contact
888	process value output, freely configurable
(4) Output II	
000	no output
310	relay, changeover contact ²
888	process value output, freely configurable ²
(5) Supply voltage	
22	20 — 53 V AC/DC, 48 — 63/0 Hz
23	110 — 240 V AC +10%/-15%, 48 — 63 Hz
(6) Interface²	
00	no interface
54	serial interface RS422/RS485, MODbus/Jbus protocol ²
64	Profibus-DP ²
(7) Extra codes	
000	none
015	logic output 0/12 V DC, instead of standard 0/5 V DC

Order example

(1)	(2)	(3)	(4) ²	(5)	(6) ²	(7)
202530/	..	- ...	- ...	, ..	- ..	/ ...

¹ **Generally**, the following configurations can be freely selected by the user on **all** instruments of Type 202530:
controller off / limit controller / pulse width controller with P, PI, PD, PID control action / pulse frequency controller with P, PI, PD, PID control action / modulating controller.

The variations listed in the type designation are simply factory default settings!

² If output II (4) = “310” or “888”, then the interface option (6) “54” or “64” is not possible (or the other way round).

5 Instrument description

5.1 Technical data

Analog input 1	Input resistance $\geq 10^{12} \Omega$ Insulation resistance of the reference system connection to ground $> 10^7 \Omega$ according to DIN 19 265 For all the usual pH electrodes, pH antimony electrodes, metal electrodes, reference electrodes or combination electrodes
Analog input 2	Pt100 or Pt1000 resistance thermometer, in 2-wire or 3-wire circuit, -50 to +250°C Measurement display in °C or °F (option)
Lead compensation, analog input 2	The lead resistance can be compensated in software by a correction of the process value. This is not required if the resistance thermometer is connected in a 3-wire circuit. Alternatively, when a resistance thermometer is connected in a 2-wire circuit, lead compensation can be provided by using an external compensation resistor.
Logic input 1	The following functions can be assigned as selected: Key inhibit, setpoint switching, alarm stop, alarm time reset, hold, reverse hold, freeze measurement, range expansion (x10), no function for logic input 1.
Logic input 2	As for logic input 1.
Measurement and control range	-1.00 to 14.00 pH freely selectable; deviation from characteristic $\leq 0.25\%$ of range
Ambient temperature error	$\leq 0.15\%$ per 10 °C
Reference temperature	25°C
Temperature display	-50 to +250°C (option °F); deviation from characteristic $\leq 0.25\%$ of range
Outputs	A maximum of 5 outputs is available:
Output 1 / 2 relay (standard)	Make contact (n.o., can also be configured as n.c. break contact) Contact rating: 3A, 250V AC, with resistive load Contact life: $> 5 \times 10^5$ operations at rated load Status indication: relay K1 => LED K1; relay K2 => LED K2

5 Instrument description

Output 4 logic output (standard)	0/5V (standard) 0/12V (option) Status indication:	$R_{load} \geq 250\Omega$ $R_{load} \geq 650\Omega$ LED K4
Output 3 or output 5 process value output (option)	Can be used as analog process value output or as proportional controller. 0(2) — 10V $R_{load} \geq 500\Omega$ 0(4) — 20mA $R_{load} \leq 500\Omega$ electrically isolated from the inputs: $\Delta u \leq 30V$ AC $\Delta u \leq 50V$ DC	
Output 3 or output 5 relay (option)	(changeover contact) Contact rating: Contact life: Status indication:	3A, 250V AC, with resistive load > 5×10^5 operations at rated load LED K3
Output 5, interface RS422 / RS485 (option)	electrically isolated; baud rate: 4800 / 9600bps; Protocol: MODbus/Jbus or Profibus-DP	

5.1.1 General controller data

A/D converter	resolution > 15 bit
Controller type	Output 1 and output 2: limit controller, pulse width or pulse frequency controller, modulating controller freely configurable and mixable K3 / K5: proportional controller
Control action	P, PI, PID or PD freely configurable and mixable
Sampling time	210msec
Meas. circuit monitoring	Input 1: out-of-range, sensor monitoring Input 2: out-of-range, probe short-circuit, probe break The outputs move to a defined (configurable) status.
Data backup	EEPROM
Supply voltage	110 — 240 V AC +10%/-15%, 48 — 63 Hz or 20 — 53 V AC/DC, 48 — 63/0 Hz


5 Instrument description

Power consumption	approx. 8VA
Electrical connection	via gold-plated faston connectors to DIN 46 244/A; 4.8mm x 0.8mm pH combination electrode / glass electrode / metal combination electrode or metal electrode via BNC socket
Permissible ambient temperature	0 to +50°C
Permissible ambient temperature limits	-10 to +55°C
Permissible storage temperature	-40 to +70°C
Climatic conditions	rel. humidity $\leq 75\%$, no condensation
Enclosure protection	to EN 60 529, front IP65 / back IP20
Electrical safety	to EN 61 010, clearance and creepage distances for - overvoltage category II - pollution degree 2
Electro-magnetic compatibility (EMC)	to EN 61 326
Housing	panel-mounting housing in non-conductive plastic to DIN 43 700, base material ABS, with plug-in controller module
Operating position	unrestricted
Weight	approx. 320g

5 Instrument description


5.2 Dimensions

Type 202530/...



5.3 Optional accessories

Additional housing, no door at front, enclosure IP65, Type 2FGE-125-2/125




Restricted external temperature range!

The ambient temperature for the surface-mounting housing must not exceed 45°C.

5 Instrument description

Additional housing, door at front, enclosure IP65, Type 2FGE-150-2/185



Restricted external temperature range!


The ambient temperature for the surface-mounting housing must not exceed 45°C.

6.1 Location


Conditions

The location should be as free from vibration as possible. Electromagnetic fields, e. g. from motors, transformers etc. should be avoided. The ambient temperature at the location can be from 0 to 50 °C, with a relative humidity of not more than 75 %.

Panel cut-out for close mounting




6.2 Fitting



- * Fit the seal (1) that is supplied onto the body of the instrument.
- * Insert the controller from the front into the panel cut-out.
- * From behind the panel, slide the mounting brackets into the guides on the sides of the housing. The flat faces of the mounting brackets must lie against the housing.
- * Push the mounting brackets up to the back of the panel, and tighten them evenly with a screwdriver.

6 Assembly

6.3 Removing the controller module



The controller module can be removed from its housing for servicing.



- * Remove BNC plug from the back of the instrument!
- * Press together the ribbed surfaces at right and left and pull the controller module out of the housing.

6.4 Cleaning the front panel

The front panel can be cleaned with normal commercial washing, rinsing and cleaning agents.

It has a limited resistance to organic solvents (e.g. methylated spirits, white spirit, P1, xylol etc.).



Do not use high-pressure cleaning equipment!

7.1 Electrical connection



The electrical connection may only be carried out by properly qualified personnel

- ☐ The choice of cable, the installation and the electrical connection must conform to the requirements of VDE 0100 "Regulations on the Installation of Power Circuits with Nominal Voltages below 1000 V" or the appropriate local regulations.
 - ☐ The electrical connection may only be carried out by properly qualified personnel.
 - ☐ The instrument must be completely disconnected from the electrical supply if contact with live parts is possible.
 - ☐ A current-limiting resistor interrupts the supply circuit in the event of a short-circuit. Any additional external fusing of the supply should not be rated below 1A (slow).
 - ☐ The load must be fused for the maximum relay current, in order to prevent the contacts of the output relay becoming welded in the event of a short-circuit.
 - ☐ The level of electromagnetic compatibility conforms to EN 61 326.
 - ☐ Run input, output and supply cables separately and not parallel to one another.
 - ☐ Sensor and interface cables should be shielded cables with twisted conductors. Do not run them close to current-carrying components or cables. Ground shielding at one end, to the TE terminal on the instrument.
 - ☐ The TE terminal on the instrument must be earthed. This lead must have at least the same conductor cross-section as used for the supply cables. Grounding and earthing leads must be wired in a star configuration to a common earth point that is connected to the protective earth of the electrical supply. Do not loop earth or ground connections, i.e. do not run them from one instrument to another.
 - ☐ Do not connect any additional loads to the supply terminals of the instrument.
 - ☐ The instrument is not suitable for use in areas with an explosion hazard (Ex areas).
 - ☐ In addition to faulty installation, incorrect settings on the controller (setpoint, data of the parameter and configuration levels, internal alterations) can also interfere with the correct operation of dependent processes, or even cause damage. The setpoint that is reached should therefore be monitored for stability. Safety devices independent of the controller should always be provided and should be capable of adjustment by specialist personnel only. Please observe the relevant safety regulations for such matters.
 - ☐ The measurement inputs of the controller must not exceed a maximum potential of 30 V AC or 50 V DC against TE.
 - ☐ Sensor leads should only be implemented as uninterrupted cables (**not** routed through terminal strips etc.).
 - ☐ If frequent relay switching is expected (> 5/min), the system must be fitted with appropriate suppressor devices against switching interference.
-

7 Installation




After the supply voltage has been applied, the instrument will operate according to the factory-set parameters (unless the instrument was ordered with “controller off”).

It is therefore advisable to program the instrument as required **before connecting the actuators**.




⇒ Chapter 9 “Operation”, page 23ff.






7.2 Connection diagram



Outputs	K	Terminal assignments	Symbol
Relay 1 (K1) Status indication LED K1	1	23 common 22 make (n.o.)	
Relay 2 (K2) Status indication LED K2	2	21 common 20 make (n.o.)	
Relay 3 (K3) Status indication LED K3 or process value output	3	16 break (n.c.) 15 common 14 make (n.o.)	
		15 - 14 +	

7 Installation

Outputs	K	Terminal assignments	Symbol
Logic output 1 (K4) Status indication LED K4	4	19 – 17 +	
Relay 4 (K5) no status indication or process value output	5	3 break (n.c.) 2 common 1 make (n.o.)	
		1 + 2 -	


Inputs	Terminal assignments	Symbol
pH combination electrode	BNC socket	
pH electrode with separate reference system	BNC socket	
Reference electrode	8	
Resistance thermometer in 3-wire circuit	9 10 11	
Resistance thermometer in 2-wire circuit	9 10 11	

7 Installation


Inputs/outputs		Terminal assignments		Symbol
Serial interface RS422 (option)	RxD	5	RxD + Receive data	
		4	RxD –	
	TxD	2	TxD + Transmit data	
		1	TxD –	
	GND	3	GND	
Serial interface RS485 (option)	+	2	TxD/RxD	
	-	1	+ TxD/RxD –	
	GND	3	GND	
Serial interface Profibus-DP (option)	VP	4	supply voltage plus, (P5V)	
	RxD/TxD-P	1	receive/transmit data positive, B conductor	
	RxD/TxD-N	2	receive/transmit data negative, A conductor	
	DGND	3	Ground for data transmission	
Logic input 1		13 19		
Logic input 2		12 19		
Supply voltage see nameplate	AC/ DC	AC: L1 phase N neutral TE technical earth	DC: L + L –	

7.3 Assembling the BNC plug


Procedure



- * Strip the external insulation from the cable



- * Push the cable through the screw fitting (1), washer (2), seal (3) and braid clamp (4).
- * Spread the braiding over the braid clamp (4).
- * Cut off any extra braiding.
- * Remove the black part-conductive coat (5).
- * Remove the inner insulation (6).



Do not use solder flux!

- * Solder the contact (7) to the inner conductor.
- * Push the connector body (8) onto the cable, engaging and tightening the screw fitting (1).

8 Commissioning

8.1 Self-test



After the supply voltage has been applied, the instrument will operate according to the factory-set parameters.
(unless the instrument was ordered with “controller off”)

It is therefore advisable to program the instrument as required **before connecting the actuators.**

⇒ Chapter 9 “Operation”, page 23.

After the supply voltage has been applied,

the instrument performs a self-test, during which all displays will light up.

OK

If the self-test was OK, then the instrument switches over to the measurement mode in about 10 seconds.

The measured pH value is displayed, as is the measured temperature (if the temperature sensor has been connected and configured); the controller operates according to the factory-set parameters!

In measurement mode, manual operation, hold, and calibration can be activated, as well as the display of the software revision level and the unit (°C / °F) for the temperature input.


Error

If an error code (e.g. F010) or “Err” is displayed,

⇒ Chapter 21 “Warnings – Errors”, page 64ff.

9.1 Basics

Displays and keys

	
(1) Display: The instrument has been reconfigured from “pH” to “redox”	(6) PGM key for selection of parameters and confirmation of entries, or for manual operation of relay K3.
(2) Status indicators (yellow) for outputs 1 to 4 ¹ LED “K1” => relay K1 LED “K2” => relay K2 LED “K3” => optional relay K3 LED “K4” => logic output K4	(7) 4-digit temperature display (LED, green, 8mm high)
(3) Increment key for altering parameters or manual operation of relay K2 or K5	(8) 4-digit process value indication (LED, red, 13mm high)
(4) Decrement key for altering parameters or manual operation of relay K1 or K4	(4) “CAL”: Initiating electrode calibration + (1-point or 2-point calibration) (6)
(5) EXIT key to leave the levels	(3) Initiate manual operation or hold + (5)

¹LED K3 has no function if the instrument was ordered with process value output (output “888”).

9 Operation

9.2 Principle of operation

Operating modes and states

Measurement mode (normal operation)	The process value and temperature are displayed.
Self-test (after power-on)	All indicators light up; the temperature display blinks.
Manual operation	The process value display continually switches between the process value and the text "HAnd", the temperature is displayed.
Hold operation	The process value display continually switches between the process value and the text "HoLd", the temperature is displayed.
Operation, parameters, configuration	The temperature display shows the parameters from the various levels; the process value display shows the corresponding values and codes.
Error	The temperature display continually switches between the temperature and the error code (e.g. F010), ⇒ Chapter 21 "Warnings – Errors", page 64ff.

Levels

The instrument functions are arranged in four levels (see diagram on next page):

- Measurement mode
- Operating level
- Parameter level
- Configuration level

Measurement mode¹ (normal operation)

The measurements are displayed at this level. Manual operation, hold and calibration can be activated.

Operating level¹

Setpoints, alarm tolerance, alarm delay and the limits for the limit comparators are entered and displayed at this level.

Parameter level¹


Controller parameters and other settings are programmed here. The display of the individual parameters depends on the type of controller action.

Configuration level¹

The basic functions of the instrument are configured at this level.

¹ Entries can only be made after the correct code word has been entered.
⇒ "Unlocking the levels", page 27.

9.3 Operation within levels



¹ A change of level can only take place after stepping through all the parameters of the level concerned.

9 Operation

9.4 General



Level protection

Changes at the operating level, parameter level and configuration level can only be made after entering a code word,
⇒ “Unlocking the levels”, page 27.

The code word has been entered correctly if the decimal point in the temperature display starts to blink when a parameter has been selected for modification.

Within a level, you can step on to the next parameter by pressing the key.



Cancel

You can change back to the measurement mode at any time, by pressing the key. For parameters that have been altered, but **not** confirmed by , the changes will **not** be accepted.



Time-out

The controller will automatically return to the measurement mode if no operation occurs for about 50 seconds. For parameters that have been altered, but **not** confirmed by , the changes will **not** be accepted.

Exception: Time-out does not apply during calibration!

Parameter entry

The entry and modification of parameters and setpoints is made continuously. The value changes at a faster rate if the key is kept pressed for a longer time.

- * Increase the value with
- * Decrease the value with



The value is only altered within the permissible range of values.

- * Accept the entry with – the upper display “winks” to confirm it (the display switches off briefly)

or

- * cancel with

Entering a configuration parameter or code word

- * Select the digit with (digit blinks)
- * Alter the code with
- * Accept the change with – the upper display “winks” to confirm it (the display switches off briefly)

or

- * cancel with

9.5 Programming

Procedure

The following procedure is recommended to avoid a “time-out” (50 seconds without an action) while entering data:

- * Enter all the changed parameter values and codes in the table
⇒ Chapter 22.1 “Programming the controller”, page 67ff.
- * Unlock all the affected levels, see below.
- * Program all the settings right through from top to bottom, in one session
- * Inhibit all the levels, see below.



Depending on the type of controller that is configured, some parameters cannot be set and will therefore not be displayed.

After changing the controller type (C211), the controller parameters must be checked.

⇒ Chapter 13.1 “Settings”, page 36ff.

Unlocking the levels

Initial condition: The instrument is in the measurement mode.

- * Press the briefly and repeatedly, until “CodE” appears in the lower display.
- * Use the and keys to set the required code.

Function	Code word ¹
Enable operating level, CAL, and manual activation of “hold”	0110
Enable operating and parameter levels	0020
Enable all levels	0300
Activate edit protection	xxxx ²

- * Press the key (confirmation) – “0000” appears in the display.

The code word has been entered correctly if the decimal point in the temperature display starts to blink when a parameter has been selected for modification.



¹ Code word 0020 includes 0110; code word 0300 includes 0020 and 0110.

² The relevant levels remain enabled until the edit protection is reactivated, either by entering a “wrong” code word (other than 0000) or the supply voltage to the instrument is switched off and then on again.

10 Controller

10.1 Configuration



For an explanation of the terminology used,
⇒ Chapter 20 “Glossary”, page 57ff.

Possible combinations

The control functions of outputs 1 and 2 can be freely combined¹:

- Controller off
- Limit controller
- Pulse width controller
- Pulse frequency controller

¹ Exception: When using a modulating controller, outputs 1 und 2 must have the same configuration.

The controller functions are determined by the following parameters:


Configuration level ¹					Parameter level ²	Operating level ³
C211	C212	C212	C213	C214		
Controller off	--	--	--	--	--	--
Limit controller	MIN / MAX contact	make / break contact	--	--	Switching differential HYS Pull-in delay Ond Drop-out delay Ofd	Setpoint SP(r)
Pulse width controller	MIN / MAX contact	make / break contact	--	--	Proportional band Pb Derivative time dt Reset time rt Minimum ON time tr Pulse period CY Output level limit Y1 or Y2	Setpoint SP(r)
Pulse frequency controller	MIN / MAX contact	make / break contact	--	--	Proportional band Pb Derivative time dt Reset time rt Minimum pulse width tr Maximum pulse frequency Fr Output level limit Y1 or Y2	Setpoint SP(r)
Modulating controller	MIN / MAX contact	make / break contact	--	--	Proportional band Pb Derivative time dt Reset time rt Minimum ON time tr Pulse period CY Output level limit Y1 or Y2 Actuator time tt	Setpoint SP(r)
Proportional controller	MIN / MAX contact	make / break contact	Proportional controller 1	Proportional controller 2	Proportional band Pb Derivative time dt Reset time rt Output level limit Y1 or Y2	Setpoint SP(r)

¹ ⇒ Chapter 14.6 “Controller options - C211”, page 42 or
 ⇒ Chapter 14.7 “Controller outputs - C212”, page 43 or
 ⇒ Chapter 14.8 “Other outputs I - C213”, page 44 or
 ⇒ Chapter 14.9 “Other outputs II - C214”, page 45.

² ⇒ Chapter 13 “Parameter level”, page 36ff.

³ ⇒ Chapter 12 “Operating level”, page 35.

Example break / make contact



		Range I		Range II		Range III	
		LED	contact	LED	contact	LED	contact
MIN	make contact	on	1	off	0	off	0
	break contact	on	0	off	1	off	1
MAX	make contact	off	0	off	0	on	1
	break contact	off	1	off	1	on	0

Configuration notes

Both outputs (K1 / K2) can be configured as pulse width or pulse frequency outputs (or as a combination).

Switching action K1 / K2	Setpoints w1 / w2
min / min	w1 < w2
min / max	w1 < w2
max / max	w1 > w2
max / min	w1 > w2

10 Controller

10.2 Controller optimization


Optimum adjustment

The optimum adaptation of the controller to the control loop can be tested by recording the starting phase.


The following diagrams (referred to the PID action) indicate where the adjustments may be incorrect, and how they can be rectified.

It can be seen that a slower control action with higher stability can be achieved by increasing either the proportional band P_b or the reset time r_t .


A smaller proportional band P_b and / or a shorter reset time r_t will result in a control action with less damping.




optimum




r_t, dt too small



r_t, dt too large



P_b too small



P_b too large

11.1 Preparation

General	The electrode parameters of a pH combination electrode are subject to manufacturing tolerances and variations depending on usage. To compensate for these changing electrode parameters, the transmitter offers two calibration procedures:
1-point calibration	In 1-point calibration, only the electrode zero is freshly determined using a buffer solution (solution with a known pH value). Problems arising from an incorrect electrode slope will not be detected by the user! This method should only be adopted in cases where the electrode is not subject to significant chemical or mechanical influences.
2-point calibration	2-point calibration makes a fresh determination of the electrode zero and slope using two buffer solutions. This method should be given preference!
Manual entry	In addition to the calibration procedure described above, the transmitter offers the facility of manually entering the zero point and slope (as determined by a laboratory, for example).
Temperature	The measurement of the pH value depends on temperature; the temperature of the solution to be measured must therefore be known for calibration. The temperature can either be measured automatically, with a Pt100 or Pt1000 temperature probe, or set manually by the user. Cancel You can change back to the measurement mode at any time, by pressing the  key.
Preparation for calibration	Before the <u>first</u> calibration, the following has to be determined: - the type of temperature acquisition during calibration - the calibration procedure (1-point or 2-point calibration) - process value output is frozen or not during calibration  If subsequent calibrations are carried out with the same settings, the parameters mentioned above will not have to be reconfigured.

11 Calibration

Select type of temperature acquisition

The instrument is in the measurement mode.

- * Unlock the configuration level, if necessary,
⇒ “Unlocking the levels”, page 27, (code word 0300).
- * Press the  key twice, for more than 2 seconds, to access the configuration level.
The lower display shows “C111”.

Use the  and  keys to set the configuration parameter:

Type of temperature acquisition	X	X	X	0
Manual temperature compensation				0
Automatic temperature compensation with Pt100				1
Automatic temperature compensation with Pt1000				2

- * Press the  key (confirmation)
- * Press the  key (return to the measurement mode).

Calibration with / without “frozen process value output”

“Freezing” the process value output means that, during calibration, the output signal is held at the value that was produced immediately before calibration started. This is to avoid an uncontrolled reaction from any PLC that may be connected to the output of the transmitter.

While the process value output is frozen, the lower display shows “donE” after the last calibration step, and the upper display shows the latest measurement. The process value output remains unchanged!

After the electrode has been installed once more, the  key must be pressed again. The process value output is now coupled to the display again.



The factory setting is: “Calibration without frozen process value output”.

Select calibration procedure

- * Press the  key repeatedly, until “C211” appears in the lower display.

Use the  and  keys to set the configuration parameter:

Calibration procedure	X	X	0	X
1-point calibration, process value output not frozen			0	
1-point calibration, process value output frozen			1	
2-point calibration, process value output not frozen			2	
2-point calibration, process value output frozen			3	

- * Press the  key (confirmation)
- * Press the  key (return to the measurement mode).

11.2 One-point calibration

You will need	- a buffer solution with a pH value which roughly corresponds to the medium measured later. - a thermometer, if you want to use manual temperature compensation. - a Pt100 or Pt1000 temperature probe, if you require automatic temperature compensation.
Initial condition	A pH combination electrode, or a glass electrode and a reference electrode, is attached to the type 202530 transmitter, as well as a Pt100 or Pt1000 temperature probe (if required), ⇒ Chapter 7.1 “Electrical connection”, page 17ff. Select calibration procedure, ⇒ Chapter 11.1 “Preparation”, page 31ff. The operating level is unlocked, ⇒ “Unlocking the levels”, page 27, (code word 0110) The instrument is in the measurement mode, ⇒ “Operating modes and states”, page 24.
Calibration	* Press the  +  (Cal) keys The lower display shows “°C”. If the decimal point flashes, manual temperature acquisition is configured. * Immerse the pH electrode and, if required, the temperature probe in the buffer solution. * Set the temperature of the buffer solution with the  or  keys. * If the decimal point does not flash, then automatic temperature acquisition is configured * Wait until the temperature reading has stabilized. * Press the  key. The lower display shows “Cal1” with the decimal point flashing. * When the pH value display has stabilized, set the displayed value to the value of the reference buffer using the  or  keys. * Press the  key. The instrument stores the new zero. The instrument is in the measurement mode again.  If, on completion of calibration, the instrument shows “Err” in the temperature display, ⇒ Chapter 21.1 “Messages”, page 64ff.

11 Calibration

11.3 Two-point calibration

You will need	- a buffer solution, pH 7, for example - a buffer solution with a pH value that differs from the first buffer solution by at least 2 pH, for instance pH 10. Both buffer solutions must have the same temperature. - a thermometer, if you want to calibrate using manual temperature compensation. - a Pt100 or Pt1000 temperature probe, if you want to calibrate with automatic temperature compensation.
Initial condition	A pH combination electrode, or a glass and a reference electrode, is attached to the type 202530 transmitter, as well as a Pt100 or Pt1000 temperature probe (if needed), ⇒ Chapter 7.1 “Electrical connection”, page 17ff. Select calibration procedure, ⇒ Chapter 11.1 “Preparation”, page 31ff. The operating level is unlocked, ⇒ “Unlocking the levels”, page 27, (code word 0110) The instrument is in the measurement mode, see “Operation / Basics / Operating modes and states”, page 20.
Calibration	* Press the  +  (Cal) keys The lower display shows “°C”. If the decimal point flashes, manual temperature acquisition is configured. * Immerse the pH electrode and, if required, the Pt100 or Pt1000 temperature probe in the first buffer solution (pH 7). * With manual temperature acquisition, set the temperature of the buffer solution using the  or  keys. * If the decimal point does not flash, then automatic temperature acquisition is configured * Wait until the temperature reading has stabilized. * Press the  key. The lower display shows “Cal1” with the decimal point flashing. * When the pH value display has stabilized, use the  or  keys to set the displayed value to the value of the first reference buffer. * Press the  key. The lower display shows “Cal2” with the decimal point flashing. * Take the pH electrode and, if necessary, the temperature probe out of the first buffer solution and rinse with water. * Immerse the pH electrode and the Pt100 or Pt1000 temperature probe (if required) in the second buffer solution. * When the pH value display has stabilized, use the  or  keys to set the displayed value to the value of the second reference buffer. * Press the  key. The instrument stores the new zero and the new slope. The instrument is in the measurement mode again.

12.1 Settings

Preconditions

How to access the operating level, or leave this level,
⇒ Chapter 9.2 “Principle of operation”, page 24ff.

The operating level must be unlocked,
⇒ “Unlocking the levels”, page 27, (code word 0110).



It is possible that not all of the following parameters are needed or displayed, depending on the configuration of the controller functions.



For an explanation of the terminology used,
⇒ Chapter 20 “Glossary”, page 57ff.

How to configure controllers,
⇒ Chapter 10.1 “Configuration”, page 28ff.

Designation	Parameter (display)	Value range	Factory setting	displayed if ... is configured	see Configuration parameter
Setpoint 1	SP(r)1	-1.00 to 14.00 pH	-1.00	K1	C211
Setpoint 2	SP(r)2		14.00	K2	
Setpoint 3	SP(r)3		-1.00	Setpoint changeover	C112
Setpoint 4	SP(r)4		14.00		
Code word	CodE	4-digit	0000		
Limit SP A (K1)	SP A	-1.00 to 14.00 pH or -50 to 250°C	-1.00	K1	C214
Limit SP b (K2)	SP b			K2	
Limit SP C (K3)	SP C			K3	C213
Limit SP d (K4)	SP d			K4	
Limit SP E (K5)	SP E			K5	C214
Temperature for compensation (manually adjustable or automatic, depending on the configuration)	InP2	(°C)	25		C111
Alarm tolerance	AL1	0.00 to 99.99 pH	0	Controller alarm messages	C211 or C213
Alarm delay	AL2	0 to 9999 sec	300		

13 Parameter level

13.1 Settings



If a number of instrument parameters have to be reconfigured,
⇒ Chapter 22.1 “Programming the controller”, page 67ff.

Preconditions

How to access the parameter level, or leave this level,
⇒ Chapter 9.2 “Principle of operation”, page 24ff.

The parameter level must be unlocked,
⇒ “Unlocking the levels”, page 27, (code word 0020).



It is possible that not all of the following parameters are needed or displayed, depending on the configuration of the controller functions.



For an explanation of the terminology used,
⇒ Chapter 20 “Glossary”, page 57ff.

How to configure controllers,
⇒ Chapter 10.1 “Configuration”, page 28ff.

Parameter	Display	Value range	Factory setting	displayed if ... is configured
Proportional band 1	Pb1	0.01 to 99.99 pH	7.00	Relay 1, pulse frequency or pulse width C211
Proportional band 2	Pb2			Relay 2, pulse frequency or pulse width C211
Derivative time 1	dt1	0 to 9999 sec	0	Relay 1, pulse frequency or pulse width C211
Derivative time 2	dt2			Relay 2, pulse frequency or pulse width C211
Reset time 1	rt1			Relay 1, pulse frequency or pulse width C211
Reset time 2	rt2			Relay 2, pulse frequency or pulse width C211
Minimum ON time 1 (for limit controller or pulse width controller) or minimum pulse width 1 (for pulse frequency controller)	tr1	0.2 to 999.9 sec	0.2	Controller 1, pulse width C211
				Pulse frequency C211
Minimum ON time 2 (for pulse width controller) or minimum pulse width 2 (for pulse frequency controller)	tr2			Relay 2, pulse width C211
				Pulse frequency C211

13 Parameter level

Parameter	Display	Value range	Factory setting	displayed if ... is configured	
Switching differential 1	HYS1	0.00 to 99.99 pH or °C	0.30	Relay 1, limit value	C211
Switching differential 2	HYS2			Relay 2, limit value	C211
Switching differential 3	HYS3			Relay 3, limit value	C213
Switching differential 4	HYS4			Relay 4, limit value	C213
Switching differential 5	HYS5			Relay 5, limit value	C214
Pull-in delay 1	Ond1	0.00 to 999.9 sec	1.0	Relay 1, limit value	C211
Pull-in delay 2	Ond2			Relay 2, limit value	C211
Pull-in delay 3	Ond3			Relay 3, limit value	C213
Pull-in delay 4	Ond4			Relay 4, limit value	C213
Pull-in delay 5	Ond5			Relay 5, limit value	C214
Drop-out delay 1	Ofd1		0.2 sec	Relay 1, limit value	C211
Drop-out delay 2	Ofd2			Relay 2, limit value	C211
Drop-out delay 3	Ofd3			Relay 3, limit value	C213
Drop-out delay 4	Ofd4			Relay 4, limit value	C213
Drop-out delay 5	Ofd5			Relay 5, limit value	C214
Maximum pulse frequency 1	Fr1	0 to 150 pulse/min	100	Relay 1, pulse frequency	C211
Maximum pulse frequency 2	Fr2			Relay 2, pulse frequency	C211
Pulse period 1	CY1	1.0 to 999.9 sec	20.0	Relay 1, pulse width	C211
Pulse period 2	CY2			Relay 2, pulse width	C211
Output level limit Relay 1	Y1	0 to 100%	100	Relay 1, pulse frequency or pulse width	C211
Output level limit Relay 2	Y2			Relay 2, pulse frequency or pulse width	C211
Filter constant	dF	0 to 100 sec	0.6		
Actuator time	tt	15 to 3000 sec	60	Modulating controller	C211

14 Configuration level

14.1 General

The basic functions of the instrument can be displayed and / or altered at the configuration level.



If it is necessary to reconfigure a number of instrument parameters,

⇒ Chapter 22.1 “Programming the controller”, page 67ff.



For an explanation of the terminology used,

⇒ Chapter 20 “Glossary”, page 57ff.

How to configure controllers,

⇒ Chapter 10.1 “Configuration”, page 28ff.

Preconditions

How to access the configuration level, or leave this level,

⇒ Chapter 9.2 “Principle of operation”, page 24ff.

The configuration level is unlocked,

⇒ “Unlocking the levels”, page 27, (code word 0300).

14.2 Analog inputs - C111

	a	b	c	d
C111*	1	0	0	0
Unit				
mV ¹	0			
pH	1			
Not used				
	0			
Slope				
Electrode slope (%)			0	
Electrode slope (mV/pH)			1	
Type of temperature acquisition				
Manual temperature compensation				0
Automatic temperature compensation with Pt100				1
Automatic temperature compensation with Pt1000				2

*The factory-set parameters are shown in the position boxes.



¹ After reconfiguration of the measurement unit from “pH” = pH value to “mV” = redox voltage, the operating instructions B 20.2535.0.1 (Part No. 00401713) have to be used!

14.3 Logic inputs... - C112

	a	b	c	d
C112*	0	0	0	0
Function of logic input 1¹				
No function	0			
Key inhibit	1			
Alarm stop	2			
Hold	3			
Freeze measurement	4			
Setpoint changeover	5			
Range expansion (x10)	6			
HOLD reversed	7			
Reset alarm time	8			
Function of logic input 2¹				
No function		0		
Key inhibit		1		
Alarm stop		2		
Hold		3		
Freeze measurement		4		
Setpoint changeover		5		
Range expansion (x10)		6		
HOLD reversed		7		
Reset alarm time		8		
Electrode type				
Standard electrode			0	
Special electrode (antimony)			1	
I component of the controller				
The I component of the controller is active between the two setpoints				0
The I component of the controller is not active between the two setpoints				1

*The factory-set parameters are shown in the position boxes.

¹ Function description ⇒ Chapter 18.1 “Functions”, page 54.

14 Configuration level

14.4 Serial interface... - C113

	a	b	c	d
C113*	0	1	0	0
Device address				
Address 0	0	0		
Address 1	0	1		
...				
Address 99	9	9		
Serial interface				
MODbus / Jbus, 9600 bps, no parity			0	
MODbus / Jbus, 9600 bps, odd parity			1	
MODbus / Jbus, 9600 bps, even parity			2	
MODbus / Jbus, 4800 bps, no parity			3	
MODbus / Jbus, 4800 bps, odd parity			4	
MODbus / Jbus, 4800 bps, even parity			5	
Response of the process value output to out-of-range or off-scale				
Underrange				
0%				0
0%				1
approx. -10% ¹				2
approx. -10% ¹				3

*The factory-set parameters are shown in the position boxes.

¹ For 0 — 10V and 0 — 20mA output signals, output is approx. -4% for underrange.

14.5 Other settings - C114

	a	b	c	d
C114*	0	0	0	0
Not used				
	0			
Not used				
		0		
Not used				
			0	
Electrode monitoring ¹				
Off				0
On				1

* The factory-set parameters are shown in the position boxes.



¹ The measurement is monitored for changes. If the measurement does not change within a defined period, then it can be assumed that an electrode fault (e.g. glass fracture, wiring fault, short-circuit) has occurred. A wrong alarm may be generated by operational states that are stationary or change very slowly. Electrode monitoring should then be switched off.

14 Configuration level

14.6 Controller options - C211

	a	b	c	d
C211*	2	2	2	0
Function K1¹ (output 1)				
off	0			
Limit controller	1			
Pulse width controller	2			
Pulse frequency controller	3			
Modulating controller ²	4			
Proportional controller	5			
Function K2¹ (output 2)				
off		0		
Limit controller		1		
Pulse width controller		2		
Pulse frequency controller		3		
Modulating controller ²		4		
Proportional controller		5		
Calibration procedure³				
1-point calibration, process value output not frozen			0	
1-point calibration, process value output frozen			1	
2-point calibration, process value output not frozen			2	
2-point calibration, process value output frozen			3	
Manual operation⁴				
Manual operation off				0
Manual operation enabled, switched ⁵				1
Manual operation enabled, only while the key is pressed				2
Simulated process value output 1				3
Simulated process value output 2				4

*The factory-set parameters are shown in the position boxes.

¹ Only effective if "1" is configured in C214c and / or "1" in C214d -> controller 2 or controller 1.

² If the function "K1 (output 1) Modulating controller" is selected, then the function "K2 (output 2) Modulating controller" must also be selected (and the other way round).

³ Function description, ⇨ Chapter 11 "Calibration", page 31ff.

⁴ Function description, ⇨ Chapter 15 "Manual operation", page 50.

⁵ Not possible if limit comparators have been configured.

14.7 Controller outputs - C212

	a	b	c	d
C212*	0	0	1	0
Signal K1 for overrange / hold				
Output level 0%	0			
Output level 100%	1			
Output level 50% (not for limit controller)	2			
Output accepted	3			
Signal K2 for overrange / hold				
Output level 0%		0		
Output level 100%		1		
Output level 50% (not for limit controller)		2		
Output accepted		3		
MIN / MAX contact for K1 / K2				
K1 K2				
MIN MIN			0	
MIN MAX			1	
MAX MIN			2	
MAX MAX			3	
Make / break contact				
K1 K2				
make make				0
make break				1
break make				2
break break				3

*The factory-set parameters are shown in the position boxes.

14 Configuration level

14.8 Other outputs I - C213

		a	b	c	d
C213*		8	0	3	0
Function of output 3 (relay 3 or analog output)					
No function		0			
Hold	(relay only)	1			
Alarm pulse contact	(relay only)	2			
Alarm steady contact	(relay only)	3			
MAX temperature limit comparator	(relay only)	4			
MIN temperature limit comparator	(relay only)	5			
MAX pH / redox limit comparator	(relay only)	6			
MIN pH / redox limit comparator	(relay only)	7			
Process value pH	(analog output only)	8			
Process value temperature	(analog output only)	9			
Proportional controller 1	(analog output only) ¹	A			
Proportional controller 2	(analog output only) ¹	b			
Signal for output 3 (analog process value output only)²					
0 — 20 mA		0			
4 — 20 mA		1			
0 — 10 V		2			
2 — 10 V		3			
20 — 0 mA		4			
20 — 4 mA		5			
10 — 0 V		6			
10 — 2 V		7			
Function of output 4 (logic output)					
No function				0	
Hold				1	
Alarm pulse contact				2	
Alarm steady contact				3	
MAX temperature limit comparator				4	
MIN temperature limit comparator				5	
MAX pH / redox limit comparator				6	
MIN pH / redox limit comparator				7	
Alarm monitoring of relays K1 and K2³					
K1	/	K2			
monitored		monitored			0
monitored		not monitored			1
not monitored		monitored			2
not monitored		not monitored			3

*The factory-set parameters are shown in the position boxes.

- ¹ 5xxx or x5xx must be selected in C211, SoL1 / SoL2 must be 0 and SoH1 / SoH2 must be 100.
- ² Only effective if configuration in C213a is "8", "9", "A" or "b".
- ³ A monitored relay contact (K1 / K2) triggers an alarm if the alarm tolerance + alarm delay time is exceeded, ⇨ Chapter 20 "Glossary", page 57ff.

14.9 Other outputs II - C214

		a	b	c	d
	C214*	0	0	1	1
Function of output 5 (relay 4 or analog output)					
No function	0				
Hold (relay only) ²	1				
Alarm pulse contact (relay only) ²	2				
Alarm steady contact (relay only) ²	3				
MAX temperature limit comparator (relay only) ²	4				
MIN temperature limit comparator (relay only) ²	5				
MAX pH / redox limit comparator (relay only) ²	6				
MIN pH / redox limit comparator (relay only) ²	7				
Process value pH (analog output only)	8				
Process value temperature (analog output only)	9				
Proportional controller 1 (analog output only) ³	A				
Proportional controller 2 (analog output only) ³	B				
Signal for output 5¹					
0 — 20 mA	0				
4 — 20 mA	1				
0 — 10 V	2				
2 — 10 V	3				
20 — 0 mA	4				
20 — 4 mA	5				
10 — 0 V	6				
10 — 2 V	7				
Function of output 2					
No function	0				
Controller 2 ⁴	1				
Alarm pulse contact ⁵	2				
Alarm steady contact ⁵	3				
MAX temperature limit comparator ⁵	4				
MIN temperature limit comparator ⁵	5				
MAX pH / redox limit comparator ⁵	6				
MIN pH / redox limit comparator ⁵	7				

14 Configuration level

	I
Function of output 1	I
No function	0
Controller 1 ⁶	1
Alarm pulse contact ⁷	2
Alarm steady contact ⁷	3
MAX temperature limit comparator ⁷	4
MIN temperature limit comparator ⁷	5
MAX limit comparator ⁷	6
MIN limit comparator ⁷	7

*The factory-set parameters are shown in the position boxes.

-
- ¹ Only effective if configuration in C214a is "8", "9", "A" or "b".
 - ² No optical status indication.
 - ³ 5xxx or x5xx must be selected in C211, SoL1 / SoL2 must be 0 and SoH1 / SoH2 must be 100.
 - ⁴ Enter the desired controller function in C211a.
 - ⁵ The corresponding setting must be made in C211 (x0xx).
 - ⁶ Enter the desired controller function in C211b.
 - ⁷ The corresponding setting must be made in C211 (0xxx).
-

14.10 Response for HOLD / Overrange - C215

	a	b	c	d
C215*	0	0	0	0
No function				
	0			
K5				
Inactive		0		
Active		1		
K4				
Inactive			0	
Active			1	
K3				
Inactive				0
Active				1

14 Configuration level

14.2 SoL - SoH - SPL - SPH - OFFS - nuLL - SLoP

SoL

Standard signal scaling of the analog process value output.

Start value of the range for standard signals of the process value output.

SoL1 -> Output 3

SoL2 -> Output 5

Value range:

depending on configuration: -1.00 to 14.00 pH -50.0 to +250°C

Factory setting -1.00 pH

Example 1:

4 — 20 mA should correspond to **2.00** — **9.00** pH

-> SoL = **2.00** / SoH = **9.00**

Example 2:


0 — 20 mA should correspond to **-10** to **+40**°C

-> SoL = **-10.0** / SoH = **40.0**

Example 3:

0 — 100% of the controller output should correspond to **0** — 8 V of the output signal (but the standard output signal of the controller is 0 — 10 V)

-> SoL = **0** / SoH = **120**



SoH

Standard signal scaling of the analog process value output.

End value of the range for standard signals of the process value output.

SoH1 -> Output K3

SoH2 -> Output K5

For value ranges and factory settings, see “SoL” above.

SPL

Setpoint limiting for controller setpoints.

This parameter is used to define the lower limit setting for the controller setpoints SPr1/2/3/4.

SPH

Setpoint limiting for controller setpoints.

This parameter is used to define the upper limit setting for the controller setpoints SPr1/2/3/4.

SLoP

Slope correction

The slope of the output signal of a pH electrode changes during operation. The electrode slope can be determined automatically during 2-point calibration (see chapter “Calibration”), or it can be entered manually.

Value range: 75.0 to 110.0%, if standard electrode is configured,

⇒ Chapter 14.3 “Logic inputs... - C112”, page 39.

Value range: 10.0 to 110.0%, if special electrode (antimony) is configured,

⇒ Chapter 14.3 “Logic inputs... - C112”, page 39.

Factory setting: 100.0%

nuLL

Zero point correction

The zero point of the **ideal** pH electrode is pH 7. Because of manufacturing variations, and also because the electrode parameters change during operation, the **real** electrode zero deviates from pH 7. This deviation from the ideal zero can be corrected with “nuLL”.

Value range: 5.00 to 9.00 pH if standard electrode is configured,

⇒ Chapter 14.3 “Logic inputs... - C112”, page 39.

Value range: -2.00 to 16.00 pH if special electrode (antimony) is configured,

⇒ Chapter 14.3 “Logic inputs... - C112”, page 39.

Factory setting: 7.00 pH

OFFS

Process value correction for temperature

The process value correction can be used to correct the measured value of the temperature input, either upwards or downwards.

Value range: -199.9 to 199.9°C or °F

Factory setting: 0°C

Example:

Measured value	Offset	Displayed value
34.7°C	+0.3°C	35.0°C
35.3°C	-0.3°C	35.0°C

15 Manual operation

Description In manual operation, outputs K1, K2 and K3 can be operated by hand, independently of the controller.




Manual operation is only possible if it has been configured first.
⇒ Chapter 14.6 “Controller options - C211”, page 42.
The output level limiting is effective during manual operation (except for limit controllers).

Initial condition The instrument is in the measurement mode.

15.1 Manual operation for outputs K1, K2 or K3

Activate In “manual operation 1”, outputs K1, K2 and K3 can be operated by hand.



* Press keys + for less than 1 second – this starts “Manual operation 1”. The upper LED display switches between the momentary value and the text “HAnd”, the lower display shows “nr. 1”.

* Activate or deactivate a particular output, see table

Key	Output
	K1 ¹
	K2 ¹
	K3 ²

* Return to measurement mode with

¹ Output level will be 0 / 100% for a proportional controller.
² Only while the key is pressed. Only when the third relay is fitted (“Output 310”,⇒ Chapter 4.1 “Type designation”, page 9).

15.2 Simulated process value output

Setting

When “Simulated process value output” has been configured,
⇒ Chapter 14.6 “Controller options - C211”, page 42,
the upper display shows “HAnd” alternately with 50.0 (%).

- * Use ▼ to reduce the signal at the process value output in 10% steps,
use ▲ to increase the signal at the process value output in 10% steps,

Example: Output signal 0 — 20 mA,
intended simulated output signal 8 mA
=> Setting 40%

16 Hold

16.1 Hold controller

Description

When “Hold” is activated, the relay outputs take up the status defined in the configuration parameters “Controller outputs” – C212 and “Response to HOLD / Overrange” – C215

⇒ Chapter 14.7 “Controller outputs - C212”, page 43.

⇒ Chapter 14.10 “Response for HOLD / Overrange - C215”, page 47.

Any alarm delay time that may be running is set to “0”, but no alarm is produced.


Initial condition

The operating level is unlocked,

⇒ “Unlocking the levels”, page 27. (0110).

The instrument is in the measurement mode.

Activate “Hold” (manual)



* Press [Up Arrow] + [EXIT] for longer than 2 seconds (but less than 4 seconds)

The upper LED display shows “HoLd” alternately with the momentary measurement

* Return to measurement mode by pressing [Up Arrow] + [EXIT] for longer than 2 seconds (but less than 4 seconds)




The controller outputs K1, K2 and K3 and K5 (depending on the instrument version and configuration) are set according to the configuration of C212.

The output level limiting is effective during “Hold” (except for limit controllers).

After configuration as limit comparator(s), outputs K1, K2, K3, K4 and K5 (depending on the instrument version and configuration) are set according to the configuration of C212 and C215.

17.1 Display software version and temperature unit



- * Display the software version and unit for temperature with  + 

The software version is shown in the upper display.

The unit (lower display) can be either °C or °F, (standard is °C; a conversion to °F can only be carried out at the factory).

18 Logic inputs

18.1 Functions




Setting the functions of the logic inputs,
see **“Configuration level / logic inputs...– C112”, page 36.**

Status of the logic input		
Key inhibit	The transmitter / controller can be operated from the keys on the front panel.	The transmitter / controller can not be operated from the keys on the front panel.
Alarm stop	Alarm signals are generated at the configured output.	The alarm contact is deactivated – the LED for the configured alarm output blinks.
Reset alarm time	Alarm signals are generated at the configured output.	The alarm contact is deactivated. Any alarm delay that has started to run will be set to zero and held.
Hold	Controller active	Hold, ⇒ Chapter 16 “Hold”, page 52.
Hold reversed	Hold, ⇒ Chapter 16 “Hold”, page 52.	Controller active
Measurement freeze	The measured process value for the first measurement variable is displayed.	The measured process value for the first measurement variable is frozen. ⇒ Chapter 11 “Calibration”, page 31ff.
Setpoint changeover	Setpoint pair 1 (SP1 and SP 2) is active. Display at operating level: SPr1 SPr2 SP 3 SP 4	Setpoint pair 2 (SP3 and SP 4) is active. Display at operating level: SP 1 SP 2 SPr3 SPr4
Range expansion (x10)	Process value output is linear between SoL and SoH	Process value 0 – 10% of full scale is scaled up to 0 – 100% of the process value output.

19.1 MODbus /Jbus

This interface can be used to integrate the controller into a data network. The following applications, for instance, can be implemented:

- Process visualization
- Plant/system control
- Recording/data logging



The bus system is designed around the master-slave concept. A master computer can communicate with up to 31 controllers or other devices (slaves). The interface is a serial interface using the RS422 or RS485 standards.

The following data protocols may be used:

- MODbus /Jbus protocol



see Interface Description B 20.2535.2



This interface can only be retrofitted at the factory.

19 Interface

19.2 Profibus-DP

Fieldbus


The Profibus-DP interface can be used to integrate the controller into a fieldbus system operating according to the Profibus-DP standard. This Profibus version is especially designed for communication between automation systems and decentralized peripheral devices at the field level, and optimized for speed.

Data transmission

The data transmission is made serially, using the RS485 standard.

GSD generator

GSD generator, the project-planning tool that is supplied with the package (GSD = Gerätestammdaten, i.e. basic device data), is used to make a selection of device characteristics for the controller to create a standardized GSD file that is used to integrate the controller into the fieldbus system.




For a detailed description, see the PROFIBUS-DP Interface Description B70.3560.2.1




Parameters which apply to both output K1 and K2 (e.g. tAb1 or tAb2) are only explained once.

Term	Parameter	Explanation
Actuator time	tt	The value for this parameter must be taken from the specific data for the actuator device (e.g. a motorized valve).
Alarm contact		With limit control, the active time of the outputs K1 or K2 can be monitored (dosing monitoring). If the active time exceeds an adjustable value (Alarm delay AL2), then the alarm contact is activated. With pulse width or pulse frequency control, and modulating / proportional controller, the size of the control deviation is monitored. If the control deviation exceeds the adjustable Alarm tolerance AL1, <u>and</u> remains outside this tolerance for longer than the Alarm delay AL2, then the alarm contact is activated.
Alarm delay	AL2	If the control deviation exceeds the adjustable Alarm tolerance AL1 , <u>and</u> remains outside this tolerance for longer than the adjustable Alarm delay AL2, then the alarm contact is activated.
Alarm tolerance	AL1	If the process value goes above or below the value of setpoint <u>plus/minus</u> alarm tolerance ($x > \text{SPr.} + \text{AL1}$ or $x < \text{SPr.} - \text{AL1}$) <u>and</u> remains outside these limits for longer than the Alarm delay AL2, the alarm contact is activated. Alarm tolerance is only active if pulse width, pulse frequency, modulating and / or proportional controller has been configured, ⇒ Chapter 14.6 “Controller options - C211”, page 42. If limit control is configured, then the values for the alarm tolerance will be ignored.
Break contact / make contact	C212	<u>Break contact</u>: As long as the switching condition is not fulfilled, the corresponding output is active (closed). <u>Make contact</u>: As long as the switching condition is fulfilled, the corresponding output is active (closed).
Code word	CodE	After the supply voltage has been applied, all levels are protected against accidental or unauthorized editing. If parameter settings have to be altered, the levels must be unlocked by entering a code word. A code word is also required to be able to calibrate the electrode. It is not necessary to remove the protection against editing if you just want to check the settings.
Derivative time	dt	This determines the differential component of the controller output signal. If the derivative time is set to “0”, then the control response has no differential component.
Dosing monitoring	C213	Defines whether the output K1 and / or K2 is/are monitored by the alarm contact.



20 Glossary

Term	Parameter	Explanation
Drop-out delay	OFd	The time required for the corresponding relay contact to return to the inactive status when the switching condition is <u>no longer</u> fulfilled. Brief excursions above or below the setpoint will be ignored by the controller.
Filter constant	df	The setting of this parameter is used to filter out interference or input signals which would provoke an undesirable reaction in the controller. The filter is a 2nd order digital filter. 
Hysteresis	HYS	see Switching differential
Limit controller	C211	A single-setpoint controller with pull-in and / or drop-out delay .
Logic input 1 / 2	C112	see “Logic inputs”, page 45.
Make contact / break contact	C212	<u>Make contact</u>: As long as the switching condition is fulfilled, the corresponding output is active (closed). <u>Break contact</u>: As long as the switching condition is not fulfilled, the corresponding output is active (closed).

Term	Parameter	Explanation
MAX limit comparator	C211 SP A SP b SP C SP d SP E	SP A ... E defines the switching point. Function: The output has the “active” status when the process value is above the limit value.  SP A ... E are only visible at the operating level, when at least one limit comparator has been configured. Assignment: SP A is affected by: HYS1, Ond1 and Ofd1 SP b is affected by: HYS2, Ond2 and Ofd2 SP C is affected by: HYS3, Ond3 and Ofd3 SP d is affected by: HYS4, Ond4 and Ofd4 SP E is affected by: HYS5, Ond5 and Ofd5
MIN / MAX contact	C212	<u>MIN contact</u>: The controller output is active if the process value is below the setpoint. <u>MAX contact</u>: The controller output is active if the process value is above the setpoint. For further explanation, ⇒ Chapter 10 “Controller”, page 28ff.
Minimum ON time	tr	With a limit controller, pulse width controller, or modulating controller. The value selected is determined by the technical requirements of the equipment operated by the controller (solenoid valves, dosing pumps etc.).
MIN temperature limit comparator	C211 SP A ... E	SP A ... E defines the switching point. Function: The output has the “active” status when the process value is below the limit value. For explanation, see “MAX limit comparator”.
Modulating controller	C211	A modulating controller can move a motor actuator in steps to any position from 0 — 100% of the actuator range. A modulating controller can, for instance, be used to operate motorized valves.
Output level limit	Y1 Y2	Defines the maximum output level that can be produced by the corresponding relay, for a pulse width or pulse frequency controller.
Process value x		The signal that is fed to the controller from the pH or redox electrode.



20 Glossary

Term	Parameter	Explanation
Process value input 2 (temperature)	C111	With automatic temperature acquisition (using a Pt100 or Pt1000 temperature probe), the measured temperature is shown in the lower display.
Proportional band	Pb	The range over which the output signal from a pulse width or pulse frequency controller is proportional to the control deviation. Beyond the proportional band, the controller will output the signal defined by the output level limit Y1 or Y2 .
Proportional controller	C211 C213 C214	In a proportional controller there is a continuous signal (i.e. a current or voltage) on the output. This signal can take on any intermediate value between a start value and an end value. Depending on the configuration of the instrument, this continuous signal can be in the range 0 – 10 V, 0 – 20 mA or 4 – 20 mA. Proportional controllers are used, for example, to operate actuator valves.
Pull-in delay	Ond	The time required for the corresponding relay contact to be activated when the switching condition is fulfilled. Brief excursions above or below the setpoint will be ignored by the controller.
Pulse contact / steady contact	C213	The behavior of an alarm contact. <u>Pulse contact:</u> The alarm output remains active for approx. 1 second, even if the switching condition (cause) of the alarm remains present for a longer time. The LED (for the output that was defined as the alarm output) blinks until the switching condition (the cause) of the alarm is no longer present. <u>Steady contact:</u> The alarm output remains active until the switching condition (the cause) of the alarm is no longer present. The LED blinks for the output that was defined as the alarm output.
Pulse frequency	Fr	Maximum pulse frequency (only for a pulse frequency controller) The value selected is determined by the technical requirements of the equipment operated by the controller (solenoid valves, dosing pumps etc.). The value is limited by the minimum pulse width : Pulse frequency [1/min] < (60 / minimum ON time [sec])

Term	Parameter	Explanation
Pulse frequency controller	C211	The repetition rate of the pulses depends on the output level and the controller parameters: proportional band Pb, derivative time dt, reset time rt, pulse frequency Fr and output level limits $Y1$ or $Y2$. The output signal from a pulse frequency controller can, for instance, be used to operate magnetic dosing pumps. t_r (constant)  $T (\geq 1/Fr)$ (depends on output level)
Pulse period	CY	This value is the period within which the pulse width modulation occurs (only for a pulse width or modulating controller). The value is limited by the minimum ON time t_r, see above: Pulse period [sec]> minimum ON time [sec])
Pulse width	t_r	For pulse frequency control, otherwise as minimum ON time
Pulse width controller	C211	The width of the pulses depends on the output level and the controller parameters: proportional band Pb, derivative time dt, reset time rt, pulse period CY and output level limits $Y1$ or $Y2$. The output signal from a pulse width controller can, for instance, be used to operate solenoid valves. $t_{ON} (\geq t_r)$ (depends on output level)  CY (constant)
Reset time	rt	Integral time constant – controller parameter in a PI or PID controller. The value determines the speed at which the control deviation is integrated. If the reset time is set to “0”, then the control action has no integral component.

20 Glossary

Term	Parameter	Explanation
Setpoint 1	SP(r)1	The given value that should be achieved by the control loop (referring to output K1). The setpoint pair that is fed to the controller is identified in the parameter display by (r). See also Setpoint changeover <u>Example</u> for the active setpoint pair 1 => SPr1, SPr2 and SP 3, SP 4. for the active setpoint pair 2 => SP 1, SP 2 and SPr3, SPr4.
Setpoint 2	SP(r)2	As for setpoint 1 , referring to output K2
Setpoint 3	SP(r)3	Refers to output K1. For explanation see Setpoint 1.  Only with activated setpoint changeover
Setpoint 4	SP(r)4	Refers to output K2. For explanation see Setpoint 1.  Only with activated setpoint changeover
Setpoint changeover	C112	If setpoint changeover is configured for one of the logic inputs, then setpoint pair 1 is active if the logic input is inactive, i.e. the controller uses the setpoints 1 and 2 (SPr1 and SPr2) for operation. If the logic input is active, then setpoint pair 2 is active, i.e. the controller uses the setpoints 3 and 4 (SPr3 and SPr4) for operation. Active setpoints are identified by an “r” in the parameter name (SPr1 and SPr2 as well as SP3 and SP4 if setpoint pair 1 is active).
Setpoint limiting	SPL	Setpoint limiting for controller setpoints. This parameter is used to define the lower limit setting for the controller setpoints SPr1/2/3/4.
Setpoint limiting	SPH	Setpoint limiting for controller setpoints. This parameter is used to define the upper limit setting for the controller setpoints SPr1/2/3/4.
Steady contact / pulse contact	C213	The behavior of an alarm contact. <u>Steady contact:</u> The alarm output remains active until the switching condition (the cause) of the alarm is no longer present. The LED blinks for the output that was defined as the alarm output. <u>Pulse contact:</u> The alarm output remains active for approx. 1 second, even if the switching condition (cause) of the alarm remains present for a longer time. The LED (for the output that was defined as the alarm output) blinks until the switching condition (the cause) of the alarm is no longer present.

Term	Parameter	Explanation
Switching condition		The process value goes above or below the setpoint. The switching condition is also dependent on the settings “Break contact/make contact” and “MIN/MAX contact”.
Switching differential (also <i>hysteresis</i>)	HYS	In a limit controller, this is the deviation of the process value from the setpoint that is required to trigger the switching of the control contact in response to a falling or rising process value. Limit controller MIN contact make contact active  Limit controller MAX contact make contact active 

21 Warnings – Errors

21.1 Messages

Warning / Error	Cause / behavior / action
F010	Alarm tolerance overrun/underrun and alarm delay time for the controller has elapsed. Relays K1/K2 behave as defined by the configuration C212, ⇒ Chapter 14.7 “Controller outputs - C212”, page 43. Check process value. Check controller parameters.
F011	Electrode monitoring has been activated - the measurement does not change. Check process conditions / electrode / cable / connector.
F022	Underrange. Controller goes to “Hold”, ⇒ Chapter 16 “Hold”, page 52. Check configured setpoints, ⇒ Chapter 12.1 “Settings”, page 35. Check electrode / cable / connector.
F023	Overrange. Controller goes to “Hold”, ⇒ Chapter 16 “Hold”, page 52. Check configured setpoints, ⇒ Chapter 12.1 “Settings”, page 35.
F024	With automatic temperature acquisition, a temperature was measured below -50°C or above +250°C. Controller goes to “Hold”, ⇒ Chapter 16 “Hold”, page 52. Check the connection to the resistance thermometer, ⇒ Chapter 7.1 “Electrical connection”, page 17ff.
F030	Process value output went below the minimum value (SoL) (only if output 3 and / or 5 were configured as the process value output (C213 or C214)). Check the setting, ⇒ Chapter 14.2 “SoL - SoH - SPL - SPH - OFFS - nuLL - SLoP”, page 48.
F031	Process value output went above the maximum value (SoH) (only if output 3 and / or 5 were configured as the process value output (C213 or C214)). Check the setting, ⇒ Chapter 14.2 “SoL - SoH - SPL - SPH - OFFS - nuLL - SLoP”, page 48.
F050	Parameter limits swapped for process value output: SoL is higher than SoH (only if output 3 and / or 5 were configured as the process value output (C213 or C214)). Check the setting, ⇒ Chapter 14.2 “SoL - SoH - SPL - SPH - OFFS - nuLL - SLoP”, page 48.

21 Warnings – Errors

Warning / Error	Cause / behavior / action
F053	Incorrect setpoint combination. Precondition: Both controllers must be configured as pulse width, pulse frequency or proportional controllers. The controller contacts must be configured as MIN/MIN or MAX/MAX, ⇒ Chapter 14.7 “Controller outputs - C212”, page 43. Cause: With MIN/MIN there will be an error message if $w1 > w2$. There is no error message if $w1 < w2$. With MAX/MAX there will be an error message if $w1 < w2$. There is no error message if $w1 > w2$. This also applies to the second pair of setpoints, if setpoint changeover is configured.
F060	Minimum ON time ($tr1$) is longer than the pulse period 1 (CY1) (only if controller 1 is configured as a pulse width controller), or Minimum ON time ($tr1$) is longer than 1/60 of the pulse frequency 1 (Fr1) (only if controller 1 is configured as a pulse frequency controller), ⇒ Chapter 13.1 “Settings”, page 36ff.
F061	Minimum ON time 2 ($tr2$) is longer than the pulse period 2 (CY2) (only if controller 2 is configured as a pulse width controller), or Minimum ON time ($tr2$) is longer than 1/60 of the pulse frequency 2 (Fr2) (only if controller 2 is configured as a pulse frequency controller), ⇒ Chapter 13.1 “Settings”, page 36ff.
Err	Electrode calibration (2-point) was terminated with an error. The old calibration data are retained. <u>Cause:</u> The slope (either as set or as determined during calibration) is outside the permissible range. Slope 75.0 – 110.0% (if standard electrode is configured) or slope 10.0 – 110.0% (if special electrode is configured) or The zero point (either as set or as determined during calibration) is outside the permissible range. Zero point 5.00 – 9.00 pH (if standard electrode is configured) or zero point -2.00 – 16.00 pH (if special electrode is configured) <u>Corrective action:</u> if necessary, configure special electrode (antimony), ⇒ Chapter 14.3 “Logic inputs... - C112”, page 39. and / or a fresh, correct calibration, ⇒ Chapter 11 “Calibration”, page 31ff or Alter zero point (nuLL) or slope (SLoP) from keys (e.g. only alter last digit by 1 digit and confirm with “PGM”). ⇒ Chapter 14.2 “SoL - SoH - SPL - SPH - OFFS - nuLL - SLoP”, page 48.

21 Warnings – Errors



Errors F010 to F031 and “Err” trigger an alarm; the configured alarm output will switch and the corresponding LED will blink.

With errors F022 to F024 and “Err”, the controller additionally goes to the “HoLd” condition, ⇒ Chapter 16 “Hold”, page 52.

The alarm relay does not switch as a result of one of the warnings F050 to F061, but the corresponding LED will blink.

22.1 Programming the controller

Configuration

If a number of instrument parameters have to be modified in the instrument, then it is advisable to note them in the table below, and then modify these parameters in the sequence given.



The following list shows the maximum number of parameters that can be altered.

Depending on the type and configuration, your instrument may not show some of the listed parameters.

Code words to unlock the individual levels,

⇒ “Unlocking the levels”, page 27.

Para- meter	Explanation	Factory setting	New setting	see page
Configuration level				
C111	Analog inputs	1000		38
C112	Logic inputs / probe / supply	0000		39
C113	Serial interface	0100		40
C114	Other settings	0000		41
C211	Controller options	2220		42
C212	Controller outputs	0010		43
C213	Other outputs I	8030		44
C214	Other outputs II	0011		45
C215	Response for HOLD / Overrange	0000		47
SoL1	Scaling of the standard signal – start value K3	-1.00		48
SoL2	Scaling of the standard signal – start value K5	-1.00		
SoH1	Scaling of the standard signal – end value K3	14.00		
SoH2	Scaling of the standard signal – end value K5	14.00		
SPL	Lower setpoint limit for controller values	-1.00		
SPH	Upper setpoint limit for controller values	14.00		
SLoP	Electrode slope	100.0		49
nuLL	Electrode zero	7.00		
OFFS	Process value correction for temperature	0.0		
Parameter level				
Pb1	Proportional band 1 [pH]	7.00		36
Pb2	Proportional band 2 [pH]	7.00		
dt1	Derivative time 1 [s]	0		
dt2	Derivative time 2 [s]	0		
rt1	Reset time 1 [s]	0		
rt2	Reset time 2 [s]	0		
tr1	Minimum ON time 1 [s]	0.2		
tr2	Minimum ON time 2 [s]	0.2		

22 Appendix

Para- meter	Explanation	Factory setting	New setting	see page
HYS1	Switching differential 1	0.30		37
HYS2	Switching differential 2	0.30		
HYS3	Switching differential 3	0.30		
HYS4	Switching differential 4	0.30		
HYS5	Switching differential 5	0.30		
Ond1	Pull-in delay 1 [s]	1.0		
Ond2	Pull-in delay 2 [s]	1.0		
Ond3	Pull-in delay 3 [s]	1.0		
Ond4	Pull-in delay 4 [s]	1.0		
Ond5	Pull-in delay 5 [s]	1.0		
OFd1	Drop-out delay 1 [s]	0.2		
OFd2	Drop-out delay 2 [s]	0.2		
OFd3	Drop-out delay 3 [s]	0.2		
OFd4	Drop-out delay 4 [s]	0.2		
OFd5	Drop-out delay 5 [s]	0.2		
Fr1	Maximum pulse frequency 1[pulse/min]	100		
Fr2	Maximum pulse frequency 2[pulse/min]	100		
CY1	Pulse period 1 [s]	20		
CY2	Pulse period 2 [s]	20		
Y1	Output level limit for K1 [%]	100		
Y2	Output level limit for K2 [%]	100		
dF	Filter constant [s]	0.6		
tt	Actuator time [s]	60		
Operating level				
SP(r)1	Setpoint 1 for contact K1 [pH]	-1.00		35
SP(r)2	Setpoint 1 for contact K2 [pH]	14.00		
SP(r)3	Setpoint 2 for contact K1 [pH]	-1.00		
SP(r)4	Setpoint 2 for contact K2 [pH]	14.00		
CodE	Code word to unlock the levels	s. p. 27		
SP A	Limit value SP A K1	-1.00		
SP b	Limit value SP b K2	-1.00		
SP C	Limit value SP C K3	-1.00		
SP d	Limit value SP d K4	-1.00		
SP E	Limit value SP E K5	-1.00		
InP2	Temperature display for compensation [°C]	25.0		
AL1	Alarm tolerance [pH]	0.00		
AL2	Alarm delay [s]	300		

